



City of Hohenwald 2024 ADA Transition Plan

Hohenwald Police Department

(1.)

Physical Barriers Identified:

No designated accessible parking, damage to ramp, no safety guards on ramp.

Solutions:

Designate and paint accessible parking zone and install signage. Repair concrete damage at ramp. Install appropriate guards and edge protection on ramp.

Priority Level: 1

Cost Estimate: \$2200

Anticipated Fiscal Year: 2025

(2.)

Physical Barrier Identified:

Customer service counter window exceeds minimum height.

Solution:

Modify customer service counter window

Priority Level: 2

Cost Estimate: \$300

Anticipated Fiscal Year: 2025

City Hall

(1.)

Physical Barrier Identified:

Entry doors are not easy to operate and enter from a wheelchair.

Solution:

Install push-button auto-opening door actuators, and lower threshold.

Priority Level: 1

Cost Estimate: \$4000

Anticipated Fiscal Year: 2025

Hohenwald Fire Department

In compliance

Wilhelm Tell Platz

(1.)

Physical Barrier Identified:

No identified accessible parking.

Solution:

Designate and paint accessible parking zone and install signage.

Priority Level: 2

Cost Estimate: \$2500

Anticipated Fiscal Year: 2025

(2.)

Physical Barrier Identified:

Ramp to gazebo is non-compliant. Grade is too steep.

Solution:

Install handrail.

Priority Level: 3

Cost Estimate: \$5000

Anticipated Fiscal Year: 2025

City Parking Lot - W. Linden & Maple

(1.)

Physical Barrier Identified:

Handrail needed on access ramp onto stage.

Solution:

Install handrail on stage access ramp.

Priority Level: 2

Cost Estimate: \$2000

Anticipated Fiscal Year: 2025